## NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: DATE: CERTIFICATION PROGRAM: COMPANY: CODE:

NI015848.03	
09/22/2023	
Structural	
Linea Rossa	
2749-1	

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit <u>www.namicertification.com</u>. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	<b>PRODUCT DESCRIPTION</b>	
Linea Rossa Windows and Doors	Series "LRWAD-530F"	
1850 Northwest 84th Avenue, Suite 114	Aluminum Fixed Window	
Doral, FL 33126	(Thermally Broken)	
	Configuration: OOO Glazing: IG - 5/32" Heat Strengthened Glass/5/32" Heat Strengthened Glass/0.090" SentryGlass Plus Interlayer/5/32" Heat Strengthened Glass	
	Frame: W-3200mm(126") H-2286mm(90")	
	Panel: W-1067mm(42") H-2286mm(90")	
	DLO: W-953mm(37.5") H-2172mm(85.5")	

SPECIFICATION	PRODUCT RATING
ASTM E1886-13a/19 ASTM E1996-17/20 TAS 201/202/203-94	Design Pressure: ±3840 Pa (±80 psf) Water Penetration Resistance Test Pressure: 646 Pa (13.5 psf) Wind Zone 4 - Missile Level D Large Missile Impact Rated

Product Tested By:	QAI Laboratories
Report No:	13123
Expiration Date:	<u>August 31, 2026</u>

Administrator's Signature:

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072 Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023