

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI015848.04  
**DATE:** 09/22/2023  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Linea Rossa  
**CODE:** 2749-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC)

| COMPANY NAME AND ADDRESS   | PRODUCT DESCRIPTION   |
|--|---|
| <b>Linea Rossa Windows and Doors</b><br><b>1850 Northwest 84th Avenue, Suite 114</b><br><b>Doral, FL 33126</b> | <b>Series "LRWAD-530F"</b><br><b>Aluminum Fixed Window</b><br><b>(Thermally Broken)</b><br><br>Configuration: OO<br>Glazing: IG - 5/32" Heat Strengthened Glass/5/32" Heat Strengthened Glass/0.090" SentryGlass Plus Interlayer/5/32" Heat Strengthened Glass<br><br>Frame: W-2134mm(84") H-2286mm(90")<br>Panel: W-1067mm(42") H-2286mm(90")<br>DLO: W-953mm(37.5") H-2172mm(85.5") |

| SPECIFICATION  | PRODUCT RATING  |
|--|---|
| <b>ASTM E1886-13a/19</b><br><b>ASTM E1996-17/20</b><br><b>TAS 201/202/203-94</b> | <b>Design Pressure: ±3840 Pa (±80 psf)</b><br><b>Water Penetration Resistance Test Pressure: 646 Pa (13.5 psf)</b><br><b>Wind Zone 4 - Missile Level D</b><br><b>Large Missile Impact Rated</b> |

Product Tested By: QAI Laboratories  
Report No: 13123  
Expiration Date: August 31, 2026

Administrator's Signature: \_\_\_\_\_ 

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)