

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015864.01-R1
DATE: 09/13/2023
CERTIFICATION PROGRAM: Structural
COMPANY: YKK AP America
CODE: 860-1
REVISION DATE: 04/18/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
YKK AP America, Inc. 101 Marietta Street NW, Suite 2100 Atlanta, GA 30303	StyleView® Classic Archtop Single Hung Vinyl Window Configuration: O/X Glazing: Insulating Glass (Annealed) Frame: W-902mm(35.50") H-2223mm(87.50") Sash: W-831mm(32.72") H-1103mm(43.44") DLO: W-745mm(29.34") H-1018mm(40.06")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	Class R-PG35 902 x 2223* (36 x 88*)-H Design Pressure: ±1680 Pa (±35 psf) Water Penetration Resistance Test Pressure: 251 Pa (5.25 psf)

Product Tested By: Intertek, LLC
Report No: P9542.24-550-44/P9542.25-550-44/W-2119
Expiration Date: **December 31, 2027**

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com