

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015864.03-R2
DATE: 09/14/2023
CERTIFICATION PROGRAM: Structural
COMPANY: YKK AP America
CODE: 860-1
REVISION DATE: 04/18/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|--|---|
| YKK AP America, Inc. 101 Marietta Street NW, Suite 2100 Atlanta, GA 30303 | StyleView® No Trim (StyleView® Select) Arch Top Single Hung Vinyl Window Configuration: O/X Glazing: Insulating Glass (Annealed) Frame: W-1207mm(47.5") H-2121mm(83.5") Sash: W-1137mm(44.75") H-1053mm(41.44") DLO: W-1130mm(44.5") H-1022mm(40.25") |

| SPECIFICATION | PRODUCT RATING |
|--|---|
| AAMA/WDMA/CSA 101/I.S.2/A440-17 | Class R-PG35 1207 x 2121 (48 x 84)-H Design Pressure: ±1680 Pa (±35 psf) Water Penetration Resistance Test Pressure: 260 Pa (5.43 psf) |

Product Tested By: Intertek, LLC
Report No: D6467.02-550-44/W-1836/W-2117/W-2119
Expiration Date: **December 31, 2027**

A handwritten signature in black ink, appearing to be "MD" or similar initials, written in a cursive style.

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com

NOPC-03/30/2023