

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI015871.01-R2  
**DATE:** 09/11/2023  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** YKK AP America  
**CODE:** 860-1  
**REVISION DATE:** 04/18/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>YKK AP America, Inc.</b> <b>101 Marietta Street NW, Suite 2100</b> <b>Atlanta, GA 30303</b>	<b>StyleView® Flange</b> <b>Single Hung Vinyl Window</b>  Configuration: O/X Glazing: Insulating Glass (Annealed)  Frame: W-1334mm(52.50") H-1905mm(75") Sash: W-1261mm(49.63") H-946mm(37.25") DLO: W-1181mm(46.50") H-857mm(33.75")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b>	<b>Class R-PG35 1334 x 1905 (53 x 75)-H</b> <b>Design Pressure: ±1680 Pa (±35 psf)</b> Water Penetration Resistance Test Pressure: 360 pa (7.50 psf)

Product Tested By: Intertek, PLC  
Report No: D9107.01-550-47/W-2117/W-2119  
Expiration Date: **December 31, 2027**

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be "Shi" or similar, written over a horizontal line.

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway  
Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023