

Notice of Product Certification

CERTIFICATION NO.: 1263-003
INITIAL CERTIFICATION DATE: August 7, 2023
REVISION DATE: October 11, 2023
REPORT NUMBER: QUA18001-14-C_CSSV-a
SPECIFICATION: CSA A440.2-22

COMPANY: Menuiserie Desmeules, Inc.
CODE: 1263-1
EXPIRATION DATE: September 6, 2024
PRODUCT SIMULATED BY: Veridis Solutions
AIR LEAKAGE REPORT NO.: AI-04077-A1

PRODUCT/SERIES NAME: Neo Casement **OPERATOR TYPE:** CSSV

| Product Number | Manufacturer Product Code | Emissivity (Surface #) | U-Factor (Metric) | SHGC(w) | Visible Transmittance (VT) | Air Leakage Average (L75) | Energy Rating |
|------------------|--------------------------------|------------------------|-------------------|---------|----------------------------|---------------------------|---------------|
| 1263-003-0001-01 | Clr-arg95-Clr-arg95-SG400 iu | 0.113(#5) | 1.27 | 0.42 | 0.46 | 0.1 | 36 |
| 1263-003-0002-01 | Clr-arg95-8071 su | 0.082(#3) | 1.48 | 0.46 | 0.51 | 0.1 | 34 |

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).



Administrator's Signature:

A handwritten signature in black ink, appearing to be 'S. D.', is written over a horizontal line.

National Accreditation & Management Institute, Inc.
4794 George Washington Memorial Hwy.
Hayes, VA 23072
Tel.: (804) 684-5124
nami@namiinc.com
namicertification.com