
NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO:
DATE:
CERTIFICATION PROGRAM:
COMPANY:
CODE:

NI010914.18	
10/30/2023	
Structural	
Wincore	
1640-1	

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit <u>www.namicertification.com</u>. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Wincore Window Company, LLC	Series "S-7500/7700/9900"
250 Staunton Turnpike	Vinyl Fixed Picture Window
Parkersburg, VA 26104	
	Configuration: O Glazing: Insulating Glass (Annealed)
	Frame: W-2745mm(108.07") H-1830mm(72.05")
	DLO: W-2652mm(104.41") H-1732mm(68.19")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22	Class CW-PG65 2745 x 1830 (108 x 72)-FW
AAMA/WDMA/CSA 101/I.S.2/A440-17	Design Pressure: ±3120 Pa (±65 psf)
AAMA/WDMA/CSA 101/I.S.2/A440-11	Water Penetration Resistance Test Pressure: 720 Pa (15.04psf)
CSA A440S1-17/19	Canadian Air Infiltration/Exfiltration Level: Fixed

Product Tested By: Report No: Expiration Date:

UL Laboratory Canada, Inc. AI-05914-H2 July 31, 2027

Sh

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072 Tel: (804) 684-5124 Email: <u>nami@namiinc.com</u>

NOPC-03/30/2023