

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011421.03
DATE: 10/02/2023
CERTIFICATION PROGRAM: Structural
COMPANY: Wincore
CODE: 1640-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Wincore Window Company, LLC 250 Staunton Turnpike Parkersburg, VA 26104	Series "8400" Vinyl Horizontal Sliding Window Configuration: XOX Glazing: Insulating Glass (Annealed) Frame: W-2794mm(110") H-1575mm(62") DLO: W-1257mm(49.5") H-1372mm(54")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-17	Class LC-PG40 2794 x 1575 (110 x 62)-HS Design Pressure: ±1915 Pa (±40 psf) Water Penetration Resistance Test Pressure = 467 Pa (9.75 psf)

Product Tested By: Testing Evaluation Laboratories, Inc.
Report No: TEL 02800534/W-1920
Expiration Date: **December 31, 2028**

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com