## **NOTICE OF PRODUCT CERTIFICATION**



CERTIFICATION NO: DATE: CERTIFICATION PROGRAM: COMPANY: CODE:

NI015444.04	
10/02/2023	
Structural	
ProVia Door	
1212-1	

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit <u>www.namicertification.com</u>. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION	
ProVia, LLC	Series "20 Gauge Smooth Steel	
2150 State Route 39	and Fiberglass Opaque"	
Sugarcreek, OH 44681	Inswing Entry Doors	
	(w/Panalock® 1.1 Assembly)	
	Configuration: XO & XX	
	Frame: W-1883mm(74.13") H-2481mm(97.69")	
	Panel: W-908mm(35.75") H-2411mm(94.94")	

SPECIFICATION	PRODUCT RATING
ASTM E330/E330M-14	Design Pressure: ±2400 Pa (±50 psf)

Product Tested By:	Intertek, PLC
Report No:	P3503.02-501-47
Expiration Date:	April 30, 2027

Administrator's Signature:

## NATIONAL ACCREDITATION & MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072 Tel: (804) 684-5124 Email: nami@namiinc.com

NOPC-03/30/2023