

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015445.05
DATE: 10/11/2023
CERTIFICATION PROGRAM: Structural
COMPANY: ProVia Door
CODE: 1212-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
ProVia, LLC 2150 State Route 39 Sugarcreek, OH 44681	Series "20 Ga. Smooth Steel Full Lite" Glazed Inswing Steel Entry Door (w/Zeel Trim & ODL Evolve Trim) Configuration: X Glazing: IG-Ext-1/8" Tempered Glass/Int.-1/8" Annealed Glass/0.090" PVB Saflex Interlayer/1/8" Annealed Glass Frame: W-954mm(37.56") H-2481mm(97.69") Panel: W-908mm(35.75") H-2411mm(94.94")

SPECIFICATION	PRODUCT RATING
ASTM E1886-19 ASTM E1996-20	Design Pressure: ±2400 Pa (±50 psf) Wind Zone 3 - Missile Level D Large Missile Impact Rated

Product Tested By: Intertek, PLC
Report No: P3164.01-501-47/N6797.01-501-47
Expiration Date: **October 31, 2026**

Administrator's Signature: _____


NATIONAL ACCREDITATION & MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com