

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015873  
DATE: 10/02/2023  
CERTIFICATION PROGRAM: Structural  
COMPANY: Enerlux  
CODE: 2426-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Enerlux Windows &amp; Doors, LLC</b>  1530 Pine Avenue  Crete, NE 68333	<b>Series "825"</b>  <b>Fiberglass Casement Window</b>  Configuration: X Glazing: IG-5/32" Annealed Glass/ 1/8" Annealed Glass/0.090" Eastman PVB Interlayer/1/8" Annealed Glass  Frame: W-1016mm (40") H-2134mm (84")  Vent: W-978mm (38.5") H-2096mm (82.5")  DLO: W-872mm (34.33") H-1986mm (78.19")

SPECIFICATION	PRODUCT RATING
ASTM E1886-19 ASTM E1996-20	<b>Design Pressure: ±2873 Pa (±60 psf)</b> <b>Wind Zne 4 - Missile Level D</b>

Product Tested By: Construction Consulting Laboratory  
Report No: CCL 23-102  
Expiration Date: August 31, 2027

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be "Shirley".

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)