

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015874
DATE: 10/03/2023
CERTIFICATION PROGRAM: Structural
COMPANY: Enerlux
CODE: 2426-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Enerlux Windows & Doors, LLC 1530 Pine Avenue Crete, NE 68333	Series "825 Sentry" Fiberglass Fixed Casement Window Configuration: O Glazing: IG-1/4" Tempered Glass/1/4" Tempered Glass//0.090" Kuraray SGP Interlayer/1/4" Tempered Glass Frame: W-1524mm (60") H-2743mm (108") DLO: W-1384mm (54.5") H-2604mm (102.5")

SPECIFICATION	PRODUCT RATING
ASTM E1886-19 ASTM E1996-20	Design Pressure: ±2873 Pa (±60 psf) Wind Zne 4 - Missile Level D

Product Tested By: Construction Consulting Laboratory
Report No: CCL 23-103
Expiration Date: August 31, 2027

A handwritten signature in black ink, appearing to be "Shirley".

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com