

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI015875  
**DATE:** 10/03/2023  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Enerlux  
**CODE:** 2426-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Enerlux Windows &amp; Doors, LLC</b> <b>1530 Pine Avenue</b> <b>Crete, NE 68333</b>	<b>Series "825"</b> <b>Fiberglass Fixed Casement Window</b>  Configuration: O Glazing: IG-3/16" Annealed Glass/1/8" Annealed Glass/Glass/0.090" Eastman SGP Interlayer/1/8" Annealed Glass  Frame: W-1219mm (48")    H-2134mm (84") DLO: W-1080mm (42.5")    H-1994mm (78.5")

SPECIFICATION	PRODUCT RATING
<b>ASTM E1886-19</b> <b>ASTM E1996-20</b>	<b>Design Pressure: ±2394 Pa (±50 psf)</b> <b>Wind Zne 4 - Missile Level D</b>

Product Tested By: Construction Consulting Laboratory  
Report No: CCL 23-104  
Expiration Date: August 31, 2027

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be "Shirley".

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)