

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015875.01
DATE: 10/19/2023
CERTIFICATION PROGRAM: Structural
COMPANY: Enerlux
CODE: 2426-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Enerlux Windows & Doors, LLC 1530 Pine Avenue Crete, NE 68333	Series "825" Fiberglass Fixed Picture Window Configuration: O Glazing: Insulating Glass (Annealed) Frame: W-2133mm (84") H-2133mm (84") DLO: W-2055mm (80.81") H-2055mm (80.81")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 CSA A440S1-17	Class CW-PG60 2133 x 2133 (84 x 84)-FW Design Pressure: 2880 Pa (60 psf) Positive Design Pressure: 3120 Pa (65 psf) Negative Design Pressure: 2880 Pa (60 psf) Water Penetration Resistance Test Pressure: 730 Pa (15.25 psf) Canadian Air Infiltration/Exfiltration Level: Fixed

Product Tested By: Intertek, PLC
Report No: M0973.02-750-44
Expiration Date: October 31, 2027

Administrator's Signature: _____ 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023