

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015878
DATE: 10/09/2023
CERTIFICATION PROGRAM: Structural
COMPANY: Crystal Pacific
CODE: 2018-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Crystal Pacific Windows Corporation 1850 Atlanta Avenue Riverside, CA 92507	Magnus 4500 Tilt & Turn Vinyl Window Configuration: X Glazing: Insulating Glass (Annealed) Frame: W-1219mm(48") H-1803mm(71") Vent: W-1143mm(45") H-1724mm(67.88") DLO: W-978mm(38.50") H-1556mm(61.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08	Class CW-PG95 1219 x 1803 (48 x 71)-DAW Design Pressure: 4560 Pa (95 psf) Positive Design Pressure: 4800 Pa (100 psf) Negative Design Pressure: 4800 Pa (100 psf) Water Penetration Resistance Test Pressure: 720 Pa (15.04 psf) Canadian Infiltration/Exfiltration Level: A3

Product Tested By: Intertek, PLC
Report No: B7013.07-109-47
Expiration Date: October 31, 2027

Administrator's Signature: _____ 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com