

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015878.01
DATE: 10/09/2023
CERTIFICATION PROGRAM: Structural
COMPANY: Crystal Pacific
CODE: 2018-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Crystal Pacific Windows Corporation 1850 Atlanta Avenue Riverside, CA 92507	Magnus 4500 Tilt & Turn Vinyl Window (AW) Configuration: X Glazing: Insulating Glass (Tempered) Frame: W-1524mm(60") H-2515mm(99") Vent: W-1445mm(56.88") H-2435mm(95.88") DLO: W-1207mm(47.50") H-2197mm(86.50")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08	Class AW-PG70 1524 x 2515 (60 x 99)-DAW Design Pressure: ±3360 Pa (±70 psf) Water Penetration Resistance Test Pressure: 580 Pa (12.11 psf)

Product Tested By: Intertek, PLC
Report No: B2798.02-701-44
Expiration Date: October 31, 2027

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "S.M.", written over a horizontal line.

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023