

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI015880  
**DATE:** 10/16/2023  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Shanghai Mylch  
**CODE:** 2350-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Shanghai Mylch Windows and Doors Manufacturing Co., Ltd. No. 1388 Lin Xian Road Jinshan District, Shanghai, China 201505</b>	<b>Series "EX95" Aluminum Wood Inswing Side-Hinged Door</b>  Configuration: X Glazing: Insulating Glass (Tempered)  Frame: W-1000mm(39.37") H-2200mm(86.61") Panel: W-907mm(35.71") H-2017mm(79.41") DLO: W-726mm(28.58") H-1926mm(75.83")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17 CSA A440S1-19</b>	<b>Class R-PG40 1000 x 2200 (39 x 87)-SHD Design Pressure: ±1920 Pa (±40 psf) Water Penetration Resistance Test Pressure: 290 Pa (6.02 psf) Canadian Air Infiltration/Exfiltration Level: A3</b>

Product Tested By: Intertek Testing Services Shenzhen Ltd.  
Report No: 220426005SHF-001  
Expiration Date: **October 31, 2026**

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)