

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI015882  
**DATE:** 10/19/2023  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Enerlux  
**CODE:** 2426-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Enerlux Windows &amp; Doors, LLC</b>  <b>1530 Pine Avenue</b>  <b>Crete, NE 68333</b>	<b>Enerlux Vertical</b>  <b>Fiberglass Mullion</b>  Span: 1830mm (72.06") Tributary Width: 1372mm (54.02")

SPECIFICATION	PRODUCT RATING
<b>AAMA 450-10</b>	<b>Applied Rating: Class CW-PG35</b> <b>Mulled Fenestration Rating: Class CW-PG35-MA</b> <b>Design Pressure: 1680 Pa (35 psf)</b> <b>Positive Design Pressure: 1920 Pa (40 psf)</b> <b>Negative Design Pressure: 1920 Pa (40 psf)</b> <b>Water Penetration Resistance Test Pressure: 730 Pa (15.25 psf)</b> <b>Canadian Air Infiltration/Exfiltration Level: A3</b>

Product Tested By: Intertek, PLC  
Report No: M0983.02-750-44/M0977.02-750-44/M0978.02-750-44  
Expiration Date: October 31, 2027

Administrator's Signature: \_\_\_\_\_  


## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023