

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015885
DATE: 10/23/2023
CERTIFICATION PROGRAM: Structural
COMPANY: Fleetwood
CODE: 1855-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Fleetwood Windows and Doors 1 Fleetwood Way Corona, CA 92879	Series "Edge P " Thermally Broken Aluminum Pivot Door Configuration: X Glazing: Insulating Glass (Tempered) Frame: W-1937mm(76.25") H-3581mm(141") Panel : W-1902mm(74.88") H-3505mm(138") DLO: W-1851mm(72.88") H-3416mm(134.50")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	SP-PG30 1937 x 3581 (76 x 141) Design Pressure: ±1440 Pa (±30 psf) Water Penetration Resistance Test Pressure: 220 Pa(4.59 psf)

Product Tested By: Fenestration Testing Laboratory, Inc.
Report No: T23-069
Expiration Date: June 30, 2027

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "Shu".

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023