

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015890  
DATE: 10/31/2023  
CERTIFICATION PROGRAM: Structural  
COMPANY: Moss Supply  
CODE: 206-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Moss Supply Company</b> <b>5001 North Graham Street</b> <b>Charlotte, NC 28269</b>	<b>Series "3400/3600 Fixed"</b> <b>Vinyl Fixed Window</b>  Configuration: O Glazing: Insulating Glass (Tempered)  Frame: W-1524mm(60") H-2438mm(96") DLO: W-1410mm(55.50") H-2324mm(91.50")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b>	<b>Class R-PG50 1524 x 2438 (60 x 96)-FW</b> <b>Design Pressure: ±2400 Pa (±50 psf)</b> Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf) Canadian Air Infiltration/Exfiltration Level: Fixed

Product Tested By: Molimo, LLC  
Report No: 27350.01-109-11  
Expiration Date: **October 31, 2027**

Administrator's Signature: \_\_\_\_\_  


## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)