

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI011587.06  
**DATE:** 11/15/2023  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Wincore  
**CODE:** 1640-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Wincore Window Company, LLC</b> <b>250 Staunton Turnpike</b> <b>Parkersburg, VA 26104</b>	<b>Series "8800"</b> <b>Vinyl Horizontal Sliding Window</b>  Configuration: XX Glazing: IG-Int.-Laminate-1/8" Annealed Glass/0.090"Saflex PVB Interlayer/1/8" Annealed Glass/Ext.-1/8" Annealed Glass  Frame: W-1880mm(74") H-1575mm(62") Sash: W-921mm(36.25") H-1464mm(57.63") DLO: W-824mm(32.43") H-1372mm(54")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b>	<b>Class R-PG55 1880 x 1575 (74 x 62)-HS</b> <b>Design Pressure: ±2640 Pa (±55 psf)</b> Water Resistance Penetration Test Pressure: 430 Pa (9.00 psf)

Product Tested By: Testing Evaluation Laboratory  
Report No: TEL 02802242  
Expiration Date: January 31, 2027

Administrator's Signature: \_\_\_\_\_  


## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)