

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011587.07
DATE: 11/15/2023
CERTIFICATION PROGRAM: Structural
COMPANY: Wincore
CODE: 1640-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Wincore Window Company, LLC 250 Staunton Turnpike Parkersburg, VA 26104	Series "8800" Vinyl Horizontal Sliding Window Configuration: XOX Glazing: IG-Int.-Laminate-1/8" Annealed Glass/0.090"Saflex PVB Interlayer/1/8" Annealed Glass/Ext.-1/8" Annealed Glass Frame: W-2794mm(110") H-1575mm(62") Sash: W-933mm(36.75") H-1464mm(57.63") DLO: W-838mm(33") H-1372mm(54")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11	Class R-PG50 2794 x 1575 (110 x 62)-HS Design Pressure: 2400 Pa (50 psf) Positive Design Pressure: 2640 Pa (55 psf) Negative Design Pressure: 2640 Pa (55 psf) Water Resistance Penetration Test Pressure: 360 Pa (7.50 psf)

Product Tested By: Testing Evaluation Laboratory
Report No: TEL 02802242
Expiration Date: January 31, 2027

Administrator's Signature: _____ 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com