

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013105.01-R1  
DATE: 11/13/2023  
CERTIFICATION PROGRAM: Structural  
COMPANY: Wincore  
CODE: 1640-1  
REVISION DATE: 11/16/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Wincore Window Company, LLC</b> <b>250 Staunton Turnpike</b> <b>Parkersburg, VA 26104</b>	<b>Series "5400, 7700"</b> <b>Vinyl Fixed Window</b>  Configuration: O Glazing: Insulated Glass (Annealed)  Frame: W-1219mm(48") H-1219mm(48") DLO: W-1054mm(41.50") H-1054mm(41.50")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-22</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b>	<b>Class R-PG50 1219 x 1219 (48 x 48)-FW</b> <b>Design Pressure: ±2400 Pa (±50 psf)</b> Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf) Canadian Air Infiltration/Exfiltration Level: Fixed

Product Tested By: Molimo, LLC  
Report No: 1929.03-109-12/W-2101  
Expiration Date: November 30, 2027

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023