NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014355.05

DATE: 11/13/2023

CERTIFICATION PROGRAM: Structural

COMPANY: Quaker

CODE: <u>031-1</u>

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS		PRODUCT DESC	CRIPTION
Quaker Window Products	Series "C600/C605 Two Tone"		
504 Highway 63 South	Aluminum Casement Out-Swing Window		
Freeburg, MO 65035			
		Configuratio Glazing: Insulated Gla	
	Frame:	W-1219mm(48")	H-2134mm(84")
	Vent:	W-1186mm(46.69")	H-2099mm(82.63")
	DLO:	W-1075mm(42.31")	H-1988mm(78.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08	Class AW-PG70 1219 x 2134 (48 x 84)-C Design Pressure: ±3360 Pa (±70 psf) Water Penetration Resistance Test Pressure: 580 Pa (12.11 psf)

Product Tested By: Intertek - Plano, Texas

Report No: L0630.01-801-47-R5/W-2076/W-2093

Expiration Date: June 30, 2027

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072 Tel: (804) 684-5124 nami@namiinc.com

NOPC-03/30/2023