

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014779.06
DATE: 11/14/2023
CERTIFICATION PROGRAM: Structural
COMPANY: Intus
CODE: 1817-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Intus Windows, LLC 2720 Prosperity Avenue, 400-1 Fairfax, VA 22031	Series "Supera" Polymer Fixed Window (w/Integral Mullions) Configuration: O Glazing: Insulating Glass (Annealed) Frame: W-2300mm(90.55") H-3048mm(120") DLO: (x4) W-1037mm(40.83") H-1411mm(55.55")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	Class CW-PG50 2300 x 3048 (91 x 120)-FW Design Pressure: ±2400 Pa (±50 psf) Water Penetration Resistance Test Pressure: 720 Pa (15.04 psf)

Product Tested By: Molimo Architectural Product Testing
Report No: 12200.01-106-13/12200.03-106-13/12200.05-106-13/W-2081
Expiration Date: **June 30, 2027**

Administrator's Signature:  _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com