NOTICE	OF PRODU	CT CERTIF	FICATION -	

SC CERTIFIED PRODUCT	CERTIFICATION NO: DATE: CERTIFICATION PROGRAM: COMPANY: CODE: REVISION DATE:	<u>NI015858.02-R1</u> <u>10/15/2023</u> <u>Structural</u> <u>YKK AP America</u> <u>860-1</u> 04/18/2024
TED PRO	REVISION DATE:	04/18/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit <u>www.namicertification.com.</u> NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS		PRODUCT DESCRIPTION		
YKK AP America, Inc.		StyleView® Classic		
101 Marietta Street NW, Suite 2100		Double Hung Vinyl Window		
Atlanta, GA 30303				
	Configuration: X/X Glazing: Insulating Glass (Annealed)			
	Frame:	W-1207mm(47.50")	H-1816mm(71.50")	
	Sash:	W-1136mm(44.72")	H-906mm(35.66")	
	DLO:	W-1050mm(41.34")	H-820mm(32.28")	

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	Class R-PG35 1207 x 1816 (48 x 72)-H Design Pressure: ±1680 Pa (±35 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.50 psf)

Product Tested By: Report No: Expiration Date: Intertek, PLC Q1858.06-550-44/P5942.13-550-44/W-2119 December 31, 2027

Shi

Administrator's Signature:

CCBEDIN

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC 4794 George Washington Memorial Highway Hayes, VA 23072 Tel: (804) 684-5124 Email: <u>nami@namiinc.com</u>

NOPC-03/30/2023