	<b>IO</b>	TI	CE	OF	PRC	DU	CT	CER	TIF]	<b>ICA</b>	TIO	Ν	

Sectional ACCREDITED ARD Sectional ACCREDITION Sectional ACCREDITI	CERTIFICATION NO: DATE: CERTIFICATION PROGRAM: COMPANY: CODE:	<u>NI015858.04-R1 10/15/2023 Structural YKK AP America 860-1</u>
ERTIFIED PRODUC	REVISION DATE:	<u>860-1</u> 04/18/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit <u>www.namicertification.com.</u> NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS		PRODUCT DES	CRIPTION	
YKK AP America, Inc.	StyleView® Classic			
101 Marietta Street NW, Suite 2100	Double Hung Vinyl Window			
Atlanta, GA 30303				
		Configuration Glazing: Insulating G		
	Frame:	W-749mm(29.50")	H-1867mm(73.50")	
	Sash:	W-679mm(26.72")	H-931mm(36.66")	
	DLO:	W-593mm(23.34")	H-845mm(33.28")	

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	Class R-PG50 749 x 1867* (30 x 74*)-H Design Pressure: ±2400 Pa (±50 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.50 psf)

Product Tested By: Report No: Expiration Date: Intertek, PLC Q1858.08-550-44/P5942.18-550-44/P5942.13-550-44/W-2119 December 31, 2027

Shy

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC 4794 George Washington Memorial Highway Hayes, VA 23072 Tel: (804) 684-5124 Email: <u>nami@namiinc.com</u>