

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015892
DATE: 11/01/2023
CERTIFICATION PROGRAM: Structural
COMPANY: Shanghai G-REN
CODE: 2967-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Shanghai YouNanTe Curtain Wall and Decoration Co., Ltd. 5273 Dongchuan Road Pudong New Area, Shanghai, China 200120	Series "GR85" Fiberglass Dual-Action Window Configuration: XO Glazing: Insulating Glass (Tempered) Frame: W-2900mm(114.17") H-1800mm(70.87") Sash: W-1155mm(45.47") H-1736mm(68.35") DLO: W-1623mm(63.90") H-1704mm(67.09")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	Class CW-PG45 2900 x 1800 (114 x 71)-DAW Design Pressure: ±2160 Pa (±45 psf) Water Penetration Resistance Test Pressure: 650 Pa (13.53psf)

Product Tested By: Intertek Testing Services Shenzhen Ltd.
Report No: 200327009SHF-003
Expiration Date: November 30, 2027

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be 'S.H.D.' or similar, written over a horizontal line.

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023