

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015895
DATE: 11/13/2023
CERTIFICATION PROGRAM: Structural
COMPANY: Harbin Sayyas
CODE: 2974-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Harbin Sayyas Windows Stock Co., Ltd. Xinxing Ind. Zone, Shuangcheng District, Harbin City, Heilongjiang, China 150199	Series "F120" Aluminum Clad Wood Fixed Window Configuration: O Glazing: Insulating Glass (Tempered) Frame: W-1500mm(59.06") H-1500mm(59.06") DLO: W-1384mm(54.49") H-1384mm(54.49")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	Class CW-PG45 1500 x 1500 (59 x 59)-FW Design Pressure: ±2160 Pa (±45 psf) Water Penetration Resistance Test Pressure: 580 Pa (12.11psf)

Product Tested By: Intertek Testing Services Shenzhen Ltd.
Report No: 230626008SHF-002
Expiration Date: **July 31, 2027**

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023