

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015896
DATE: 11/13/2023
CERTIFICATION PROGRAM: Structural
COMPANY: Harbin Sayyas
CODE: 2974-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|---|---|
| Harbin Sayyas Windows Stock Co., Ltd. Xinxing Ind. Zone, Shuangcheng District, Harbin City, Heilongjiang, China 150199 | Series "F120" Aluminum Clad Wood Dual-Action Window Configuration: X Glazing: Insulating Glass (Tempered) Frame: W-1200mm(47.24") H-1800mm(70.87") Sash: W-1118mm(44.02") H-1718mm(67.64") DLO: W-1011mm(39.80") H-1611mm(63.43") |

| SPECIFICATION | PRODUCT RATING |
|--|--|
| AAMA/WDMA/CSA 101/I.S.2/A440-17 | Class CW-PG45 1200 x 1800 (47 x 71)-DAW Design Pressure: ±2160 Pa (±45 psf) Water Penetration Resistance Test Pressure: 580 Pa (12.11psf) |

Product Tested By: Intertek Testing Services Shenzhen Ltd.
Report No: 230626008SHF-003
Expiration Date: **July 31, 2027**

Administrator's Signature: _____ 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023