

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015897  
DATE: 11/13/2023  
CERTIFICATION PROGRAM: Structural  
COMPANY: Upstate Door  
CODE: 2934-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Upstate Door, Inc.</b> <b>26 Industrial Street</b> <b>Warsaw, NY 14569</b>	<b>“Wood Impact Door”</b> <b>Wood In-Swing Side-Hinged Door</b> <b>w/Sidelites</b>  Configuration: OXO Glazing: IG - 3/16" Tempered Glass/1/8" Annealed Glass/0.090" Trosifol PVB Interlayer/1/8" Annealed Glass  Frame: W-2578mm(101.5") H-2502mm(98.5") Vent: W-1060mm(41.75") H-2432mm(95.75") DLO: W-832mm(32.75") H-2127mm(83.75")

SPECIFICATION	PRODUCT RATING
<b>ASTM E-330-02</b> <b>ASTM E1886-05</b> <b>ASTM E1996-05b</b>	<b>Design Pressure: ±3591 Pa (±75 psf)</b> <b>Wind Zone 4 - Missile Level D</b>

Product Tested By: ETC Laboratories, Inc.  
Report No: ETC-09-UDI-22414.0  
Expiration Date: **November 30, 2027**

Administrator's Signature: \_\_\_\_\_  


## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)