

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015904
DATE: 11/16/2023
CERTIFICATION PROGRAM: Fire
COMPANY: Vision Door
CODE: 2822-1
EXPIRATION DATE: 11/30/2027

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|---|--|
| Vision Door & Millwork, LLC 2525 Pio Nono Avenue Macon, GA 31206 | 20 Minute Positive Pressure Molded Simulated Panel Side-Hinged Side-Hinged Door Assembly Manufacturer Specific Fire Doors for Single Swing or Standard Pairs Installation in 20 Minute Locations 1/2" Minimum Latch Throw Single Swing or Standard Pairs Only Single Swing Maximum Size: 3'0" x 8'0" Standard Pairs Maximum Size: 6'0" x 8'0" Minimum Thickness: 1-3/4" |

| SPECIFICATION | PRODUCT RATING |
|---|---|
| NFPA 252 (1999) UL 10(b) (2009) CAN4-S104 (1985)(2010) UL 10(c) (2009) | 20 Minute-Positive Pressure With Hose Stream Category B Door-Additional Edge Seal Required For Use in Category C Frame (or may also be installed in Category C-Proprietary in accordance with individual manufacturer's listing) |

| TEST REPORT |
|---|
| Intertek Test Report No: 3192291COQ-005, 100211525COQ-001, 100553244COQ-002, 100581395MID-001, 101432263COQ NAMI Waiver of Retest: W-2063/W-2090 |

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124/nami@namiinc.com

NOPC-03/30/2023