NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO:
DATE:
CERTIFICATION PROGRAM:
COMPANY:
CODE:
EXPIRATION DATE:

NI015906	
11/16/2023	
Fire	
Vision Door	
2822-1	
11/30/2027	

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit <u>www.namicertification.com</u>. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Vision Door & Millwork, LLC	20-Minute Fiberglass
2525 Pio Nono Avenue	Fire Door
Macon, GA 31206	Manufacturer Specific Fire Doors for Single Swing Installation in 20 Minute Locations
	1/2" Minimum Latch Throw Single Swing Only
	Maximum Size: 3'0" x 6'8" Minimum Thickness: 1-3/4"

SPECIFICATION

NFPA 252 (2017) UL 10C (2016) CAN/ULC S104 (2015) 20 Minute-Neutral/Positive Pressure With Hose Stream Category B - Additional Edge-Sealing

System Required

PRODUCT RATING

TEST REPORT

Intertek Test Report No: 103550846MID-003, G103550846 NAMI Waiver of Retest: W-2063/W-2090

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072 Tel: (804) 684-5124 nami@namiinc.com

NOPC-03/30/2023