

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015908
DATE: 11/16/2023
CERTIFICATION PROGRAM: Fire
COMPANY: Vision Door
CODE: 2822-1
EXPIRATION DATE: 11/30/2027

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Vision Door & Millwork, LLC 2525 Pio Nono Avenue Macon, GA 31206	20-90 Minute Foam-Filled Steel Fire Door (Hollow Metal/24 or 26 Gauge/Flush or Embossed) Manufacturer Specific Fire Doors for Single or Double Swing Installation in 20 Minute Locations 1/2" Minimum Latch Throw Single or Double Swing Only Maximum Size: 6'0" x 8'0" (Must refer to listing for size/rating limitations) Minimum Thickness: 1-3/4"

SPECIFICATION	PRODUCT RATING
NFPA 252 (2012) UL 10C (2009/2016) UL 10B (2009) UBC Standard 7-2 (1994/1997) CAN/ULC S104 (2010/2015)	90 Minute-Positive Pressure Without Hose Stream 20 Minute-Positive Pressure With Hose Stream (26 Gauge Skin - 3'0" x 7'0" Maximum Size) Category B - Additional Edge-Sealing System Required

TEST REPORT
Intertek EEV No: 100754937MID-001, 100108677COQ-001, 100211525COQ-001 NAMI Waiver of Retest: W-1998/W-2028/W-2063/W-2090


 Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
 MANAGEMENT INSTITUTE, INC.**
 4794 George Washington Memorial Highway
 Hayes, VA 23072
 Tel: (804) 684-5124
nami@namiinc.com