NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015910

DATE: 11/29/2023

CERTIFICATION PROGRAM: Fire

COMPANY: Weston Wood

CODE: <u>2999-1</u>

EXPIRATION DATE: 11/29/2027

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|-----------------------------|---|
| Weston Wood Solutions, Inc. | Model "Woodgrain" |
| 300 Orenda Road | 20 Minute Category C-Proprietary |
| Brampton, ON L6T 1G2 | Composite Door Frames |
| | |
| | Manufacture Specific Fire Door Frames for Single Swing Installation in 20 Minute Locations |
| | Maximum Size: W-49.69" x H-96.85" |
| | Minimum Jamb Depth: 4.13" |

| SPECIFICATION | PRODUCT RATING | |
|--|---|--|
| CAN4 S104(2015) NFPA 252(2017) UL 10C(2016) UL 10B (2015) | 20 Minute-With Hose Stream Neutral or Positive Pressure Category C- Proprietary Frame | |
| TEST REPORT | | |
| Intertek Test Report No(s): 190228006SHF-002 | | |

dministrator's Signature:

MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072 Tel: (804) 684-5124 nami@namiinc.com

NOPC 03/30/2023