

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015911
DATE: 11/29/2023
CERTIFICATION PROGRAM: Fire
COMPANY: Weston Wood
CODE: 2999-1
EXPIRATION DATE: 11/29/2027

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Weston Wood Solutions, Inc. 300 Orenda Road Brampton, ON L6T 1G2	Model "White Cap" 20 Minute Category C-Proprietary Composite Door Frames Manufacture Specific Fire Door Frames for Single Swing Installation in 20 Minute Locations Maximum Size: W-49.69" x H-96.85" Minimum Jamb Depth: 4.13"

SPECIFICATION	PRODUCT RATING
CAN4 S104(2015) NFPA 252(2017) UL 10C(2016) UL 10B (2015)	20 Minute-With Hose Stream Neutral or Positive Pressure Category C- Proprietary Frame

TEST REPORT
Intertek Test Report No(s): 190228006SHF-001

Administrator's Signature:  _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com