

NOTICE OF PRODUCT CERTIFICATION



Company: Masonite International Corporation
 1955 Powis Road
 West Chicago, IL 60185

Certification No.: NI007077.11-R1
Certification Date: 12/06/2023
Revision Date: 04/29/2024
Expiration Date: 12/31/2026

Product: Fiberglass Impact Rated Opaque Inswing or Outswing Door w/ and w/o Impact Rated Sidelites
 Endura Trilennium or Panolock Multipoint Hardware (w/Wood Frame or Worldwide Composite
 Frame³ unless noted)

Specification: TAS 201/202/203-94/ASTM E330-02/14/M-14

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

Configuration	Inswing or Outswing	Glazed or Opaque	Maximum Size	Structural Design Pressure	Water Test Pressure	Missile Impact Rated	Test Report Number Drawing Number & Comments
X Single	I/S	Opaque	3'0" x 8'0"	+40/-45	0 psf	Yes	NCTL-210-3102-1/ATLNC 0129.02-15/ATLNC 1031.01-16 Maximum Panel Size: 3'0" x 8'0" Anchor Details-MA-FL0171-07/W-1807/W-2106/W-2107
X Single	O/S	Opaque	3'0" x 8'0"	+45/-45	3.75 psf/6.0 psf ¹ 10.5 psf ² /9.0 psf ⁴	Yes	NCTL-210-3102-1/ATLNC 0129.02-15 ATLNC 1031.01-16 Maximum Panel Size: 3'0" x 8'0" Anchor Details-MA-FL0171-07/W-1807/W-1835/W-2106/W-2107
XX Double	I/S	Opaque	6'0" x 8'0"	+40/-45	0 psf	Yes	NCTL-210-3105-1/ATLNC 0129.01-15 ATLNC 1031.01-16 Maximum Panel Size: 3'0" x 8'0" Anchor Details-MA-FL0171-07/W-1807/W-2106/W-2107
XX Double	O/S	Opaque	6'0" x 8'0"	+45/-45	3.75 psf/6.0 psf ¹ 8.25 psf ² /8.25 psf ⁴	Yes	NCTL-210-3105-1/ATLNC 0129.01-15 ATLNC 1031.01-16 Maximum Panel Size: 3'0" x 8'0" Anchor Details-MA-FL0171-07/W-1807/W-1835/W-2106/W-2107
XO/OX Single w/Sidelite	I/S	Opaque Door Glazed Sidelite	6'0" x 8'0"	+40/-45	0 psf	Door-Yes Sidelite-Yes	NCTL-210-3105-1/ATLNC 0129.01-15 ATLNC 1031.01-16 Maximum Panel Size: 3'0" x 8'0" Anchor Details-MA-FL0171-07/W-1807/W-2106/W-2107
XO/OX Single w/Sidelite	O/S	Opaque Door Glazed Sidelite	6'0" x 8'0"	+45/-45	3.75 psf/6.0 psf ¹ 8.25 psf ² /9.0 psf ⁴	Door-Yes Sidelite-Yes	NCTL-210-3105-1/ATLNC 0129.01-15 ATLNC 1031.01-16 Maximum Panel Size: 3'0" x 8'0" Anchor Details-MA-FL0171-07/W-1807/W-1835/W-2106/W-2107
OXO Single w/Sidelites	I/S	Opaque Door Glazed Sidelite	9'0" x 8'0"	+40/-45	0 psf	Door-Yes Sidelite-Yes	NCTL-210-3105-1/ATLNC 0129.01-15 ATLNC 1031.01-16 Maximum Panel Size: 3'0" x 8'0" Anchor Details-MA-FL0171-07/W-1807/W-2106/W-2107
OXO Single w/Sidelites	O/S	Opaque Door Glazed Sidelite	9'0" x 8'0"	+45/-45	3.75 psf/6.0 psf ¹ 8.25 psf ² /9.0 psf ⁴	Door-Yes Sidelite-Yes	NCTL-210-3105-1/ATLNC 0129.01-15 ATLNC 1031.01-16 Maximum Panel Size: 3'0" x 8'0" Anchor Details-MA-FL0171-07/W-1807/W-1835/W-2106/W-2107
OXXO Double w/Sidelites	I/S	Opaque Door Glazed Sidelite	12'4" x 8'0"	+40/-45	0 psf	Door-Yes Sidelite-Yes	NCTL-210-3105-1/ATLNC 0129.01-15 ATLNC 1031.01-16 Maximum Panel Size: 3'0" x 8'0" Anchor Details-MA-FL0171-07/W-1807/W-2106/W-2107
OXXO Double w/Sidelites	O/S	Opaque Door Glazed Sidelite	12'4" x 8'0"	+45/-45	3.75 psf/6.0 psf ¹ 8.25 psf ² /8.25 psf ⁴	Door-Yes Sidelite-Yes	NCTL-210-3105-1/ATLNC 0129.01-15 ATLNC 1031.01-16 Maximum Panel Size: 3'0" x 8'0" Anchor Details-MA-FL0171-07/W-1807/W-1835/W-2106/W-2107

1 -Denotes Z-Series Threshold Design 2 -Denotes High Dam Threshold Design 3-W-1815 4-Denotes Worldwide Pro T4 Threshold

National Accreditation & Management Institute, Inc./4794 George Washington Memorial Highway/Hayes, VA 23072

Tel: (804) 684-5124/nami@namiinc.com

NAMI AUTHORIZED SIGNATURE: _____