

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015913.01  
DATE: 12/05/2023  
CERTIFICATION PROGRAM: Structural  
COMPANY: Sun-Tek  
CODE: 225-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Sun-Tek Manufacturing, Inc.</b>  <b>10303 General Drive</b>  <b>Orlando, FL 32824</b>	<b>Series "ICMG III Series "</b>  <b>Aluminum Fixed Roof Skylight</b>  <b>w/Laminated Glass (Impact)</b>  <b>(Models 4949 &amp; 2549)</b>  Configuration: O  Glazing: IG-Ext.-1/8" Tempered Glass/Int.-1/8" Annealed Glass/0.090" Kuraray Trosifol PVB Interlayer/1/8" Annealed Glass  Frame: W-686mm(27")      H-1295mm(51")  DLO: W-457mm(18")      H-1067mm(42")

SPECIFICATION	PRODUCT RATING
<b>TAS 201/202/203-94</b>	<b>Design Pressure: ±3840 Pa (±80 psf)</b> Water Penetration Resistance Test Pressure: 720 Pa (15.00 psf) <b>Large Missile Impact Rated</b>

Product Tested By: PRI Construction Materials Technologies, LLC  
Report No: 2594T0001.01  
Expiration Date: October 31, 2027

Administrator's Signature: \_\_\_\_\_  


**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023