

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015913.03
DATE: 12/11/2023
CERTIFICATION PROGRAM: Structural
COMPANY: Sun-Tek
CODE: 225-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Sun-Tek Manufacturing, Inc. 10303 General Drive Orlando, FL 32824	Series "ICMG III Series " Aluminum Fixed Roof Skylight w/Laminated Glass (Impact) (Models 4949 & 2549) Configuration: O Glazing: IG-Ext.-1/8" Tempered Glass/Int.-1/8" Annealed Glass/0.090" Kuraray Trosifol PVB Interlayer/1/8" Annealed Glass Frame: W-686mm(27") H-1295mm(51") DLO: W-457mm(18") H-1067mm(42")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/1.S.2/A440-17	SKG-PG80 686 x 1295* (27 x 51*) Design Pressure: ±3840 Pa (±80 psf) Water Penetration Resistance Test Pressure: 720 Pa (15.04 psf)

Product Tested By: PRI Construction Materials Technologies, LLC
Report No: 2594T0001.02
Expiration Date: October 31, 2027

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023