

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015914  
DATE: 12/07/2023  
CERTIFICATION PROGRAM: Fire  
COMPANY: Dyke Ind.  
CODE: 452-1  
EXPIRATION DATE: 12/31/2027

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Dyke Industries</b> <b>10500 Northwest 95<sup>th</sup> Avenue</b> <b>Medley, FL 33178</b>	<b>Series “ 200PP”</b> <b>Single Leaf Fire Proof Fiberglass</b> <b>Side Hinged Door</b>  Manufacturer Specific Fire Doors for Single Swing Installation in 20 Minute Locations  1/2" Minimum Latch Throw Single Swing Only  <b>Maximum Size: 908mm x 2413mm</b> <b>Minimum Thickness: 44.5mm</b>

SPECIFICATION	PRODUCT RATING
<b>NFPA 252 (2012)</b> <b>UL 10(b) (2009)</b> <b>UBC Standard 7-2 (1997)</b> <b>UL 10(c) (2009)</b>	<b>20 Minute-Positive Pressure</b> <b>20 Minute-Neutral Pressure</b> <b>Without Hose Stream</b> <b>Category B Door-Additional Edge Seal</b> <b>Required</b> <b>For Use in Category C Frame</b> (or may also be installed in Category C-Proprietary in accordance with individual manufacturer's listing)

TEST REPORT
<b>Intertek Test Report No: 170410011SHF-BP-1</b>

Administrator's Signature: 

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124/ [nami@namiinc.com](mailto:nami@namiinc.com)