

NOTICE OF PRODUCT CERTIFICATION




CERTIFICATION NO: NI015915
DATE: 12/07/2023
CERTIFICATION PROGRAM: Fire
COMPANY: Dyke Ind.
CODE: 452-1
EXPIRATION DATE: 12/31/2027

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Dyke Industries 10500 Northwest 95th Avenue Medley, FL 33178	Series “ 4-9/16”” 20 Minute Category C Proprietary PVC Door Frame Manufacture Specific Fire Door Frames for Single Swing Installation in 20 Minute Locations 1/2" Minimum Latch Throw Single Swing Only Maximum Size: 952mm x 2438mm Minimum Thickness: 116mm

SPECIFICATION	PRODUCT RATING
NFPA 252 (2012) UL 10(b) (2009) UBC Standard 7-2 (1997) UL 10(c) (2009)	20 Minute-Positive Pressure 20 Minute-Neutral Pressure Without Hose Stream Category C- Proprietary Frame

TEST REPORT
Intertek Test Report No: 170410011SHF-BP-1

Administrator's Signature: _____ 

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124/ nami@namiinc.com