

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015917
DATE: 12/12/2023
CERTIFICATION PROGRAM: Structural
COMPANY: ViWinTech
CODE: 583-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|--|--|
| ViWinTech 2400 Irvin Cobb Drive Paducah, KY 42003 | Series "140.148 Casement" Vinyl Casement Window Configuration: X Glazing: Insulating Glass (Annealed) Frame: W-914mm(36") H-1829mm(72") Panel: W-856mm(33.69") H-1770mm(69.69") |

| SPECIFICATION | PRODUCT RATING |
|-------------------------------------|--|
| ANSI/AAMA/NWWDA 101/I.S.2-97 | C-C30 36 x72 Design Pressure: ± 1440 Pa (± 30 psf) Water Penetration Resistance Test Pressure: 580 Pa (12.00 psf) |

Product Tested By: Architectural Testing, Inc.
Report No: 54876.02-701-47
Expiration Date: December 31, 2028

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "MD".

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023