NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI015921**
DATE:	**12/12/2023**
CERTIFICATION PROGRAM:	**Fire**
COMPANY:	**Harbin Lumber**
CODE:	**2341-1**
EXPIRATION DATE:	**12/31/2027**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Harbin Lumber Company **660 Smith Road** **Lavonia, GA 30553**	**Jeld Wen 45-60 Minute** **Flush Core Side-Hinged Door** **Manufacturer Specific Fire Doors for Single & Double Swing Installation in 45-60 Minute Locations** 1/2" Minimum Latch Throw Single & Double Swing Only **Single Maximum Size: 3'6" x 7'0"** **Single Maximum Size: 3'0" x 8'0"** **Double Maximum Size: 7'0" x 7'0"** **Double Maximum Size: 6'0" x 8'0"** **Minimum Thickness: 1-3/4"**

SPECIFICATION	PRODUCT RATING
UL 10(c) (2009/2016) **CAN4 S104 (1985)** **CAN/ULC-S104 (2015)** **NFPA 252 (2012)**	**45-60 Minute-Positive Pressure w/Hose Stream** **Category A Door-No Additional Edge Seal Required** **For Use in 16 & 18 Gauge Steel Frames** (or may also be installed in Category C or Category C-Proprietary in accordance with individual manufacturer's listing)

TEST REPORT
Intertek Test Report No: G103003006MID-008, WHI-495-1607, J20017954-231, WHI-495-1456, G3043300, G3128474, G3186280, G3181954 **NAMI Waiver of Retest: W-2028**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com