NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015935

DATE: $\frac{12}{12}$

CERTIFICATION PROGRAM: Fire

COMPANY: Harbin Lumber

CODE: 2341-1

EXPIRATION DATE: 12/31/2027

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Harbin Lumber Company	20-90 Minute Foam-Filled Steel Fire Door
660 Smith Road	(Hollow Metal/24 or 26 Gauge/Flush or Embossed)
Lavonia, GA 30553	Manufacturer Specific Fire Doors for Single or Double Swing Installation in 20 Minute Locations
	1/2" Minimum Latch Throw Single or Double Swing Only
	Maximum Size: 6'0" x 8'0" (Must refer to listing for size/rating limitations) Minimum Thickness: 1-3/4"

SPECIFICATION	PRODUCT RATING
NFPA 252 (2012) UL 10C (2009/2016) UL 10B (2009) UBC Standard 7-2 (1994/1997) CAN/ULC S104 (2010/2015)	90 Minute-Positive Pressure Without Hose Stream 20 Minute-Positive Pressure With Hose Stream (26 Gauge Skin - 3'0" x 7'0" Maximum Size) Category B - Additional Edge-Sealing System Required

TEST REPORT

Intertek EEV No: 100754937MID-001, 100108677COQ-001, 100211525COQ-001 NAMI Waiver of Retest: W-1998/W-2028/W-2063/W-2090



Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072

Tel: (804) 684-5124/ nami@namiinc.com