

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015937
DATE: 12/12/2023
CERTIFICATION PROGRAM: Fire
COMPANY: Harbin Lumber
CODE: 2341-1
EXPIRATION DATE: 12/31/2027

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Harbin Lumber Company 660 Smith Road Lavonia, GA 30553	“Warm Springs 90-Minute” Flush Panel Composite Fire Doors Manufacturer Specific Fire Doors for Single or Double Swing Installation in 90 Minute Locations 1/2" Minimum Latch Throw Single or Double Swing Only Maximum Size: 8'0" x 8'0" (Must refer to listing for size/rating limitations) Minimum Thickness: 1-11/16"

SPECIFICATION	PRODUCT RATING
NFPA 252 (2012/2017) UL 10C (2009/2016) CAN/ULC S104 (2010/2015)	90 Minute-Positive Pressure With Hose Stream Category A - No Additional Edge-Sealing System Required Temperature Rise @ 30 Min: 250° F Max (Where lites do not exceed 100 in²)

TEST REPORT
Intertek Test Report No: 104142512COQ-006 NAMI Waiver of Retest: W-1985/W-1989/W-1998/W-2028

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

nami@namiinc.com

NOPC 03/30/2023