

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015940
DATE: 12/12/2023
CERTIFICATION PROGRAM: Fire
COMPANY: Harbin Lumber
CODE: 2341-1
EXPIRATION DATE: 12/31/2027

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Harbin Lumber Company 660 Smith Road Lavonia, GA 30553	Series "HM Surerock 4-9/16" 20 Minute Category C Proprietary PVC Door Frame Manufacture Specific Fire Door Frames for Single Swing Installation in 20 Minute Locations 1/2" Minimum Latch Throw Single Swing Only Maximum Size: 952mm x 2438mm Minimum Thickness: 116mm

SPECIFICATION	PRODUCT RATING
NFPA 252 (2012) UL 10(b) (2009) UBC Standard 7-2 (1997) UL 10(c) (2009)	20 Minute-Positive Pressure 20 Minute-Neutral Pressure Without Hose Stream Category C- Proprietary Frame

TEST REPORT
Intertek Test Report No: 170410011SHF-BP-1

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

nami@namiinc.com

NOPC 03/30/2023