

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015942
DATE: 12/12/2023
CERTIFICATION PROGRAM: Fire
COMPANY: Harbin Lumber
CODE: 2341-1
EXPIRATION DATE: 12/31/2027

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Harbin Lumber Company 660 Smith Road Lavonia, GA 30553	"HDF/MDF Skin w/Warm Springs Core" Wood Side Hinged Door w/X19 Adhesive Manufacture Specific Fire Doors for Single Swing Installation in 45-Minute Locations 1/2" Minimum Latch Throw Single Swing Only Maximum Size: 35.81" x 83.5" Minimum Thickness: 1.75"

SPECIFICATION	PRODUCT RATING
UL 10(c) (2021)	45 Minute-Positive Pressure With Hose Stream Category B- Additional Edge Sealing System Required

TEST REPORT
Intertek Test Report No: 105199609MID-006

Administrator's Signature: 

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

nami@namiinc.com

NOPC 03/30/2023