NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: DATE: CERTIFICATION PROGRAM: COMPANY: CODE:

| NI015945.02 | |
|-------------|--|
| 12/18/2023 | |
| Structural | |
| Quaker | |
| 031-1 | |
| | |

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit <u>www.namicertification.com</u>. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION | |
|--------------------------|----------------------------------------------------------|--|
| Quaker Window Products | Series "V300" | |
| 504 Highway 63 South | Vinyl Inswing Side Hinge Door | |
| Freeburg, MO 65035 | (w/ADA Threshold) | |
| | Configuration: X Glazing: Insulating Glass (Tempered) | |
| | Frame: W-1016mm(40") H-2134mm(84") | |
| | Panel: W-920mm(36.25") H-2072mm(81.56") | |
| | DLO: W-676mm(26.63") H-1664mm(65.50") | |

| SPECIFICATION | PRODUCT RATING |
|---------------------------------|--------------------------------------------------------------------------------|
| AAMA/WDMA/CSA 101/I.S.2/A440-17 | Class CW-PG50 1016 x 2134 (40 x 84)-SHD Design Pressure: ±2400 Pa (±50 psf) |
| | Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf) |

Product Tested By:MoReport No:273Expiration Date:Oc

Molimo, LLC 27365.01-106-11 October 31, 2027

Sh!

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072 Tel: (804) 684-5124

Email: <u>nami@namiinc.com</u>

NOPC-03/30/2023