

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014954.04  
DATE: 12/29/2023  
CERTIFICATION PROGRAM: Structural  
COMPANY: Quaker  
CODE: 031-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Quaker Window Products</b> <b>504 Highway 63 South</b> <b>Freeburg, MO 65035</b>	<b>Series "M600"</b> <b>Out-Swing Aluminum</b> <b>Architectural Terrace Door</b>  Configuration: X Glazing: Insulating Glass (Tempered)  Frame: W-1219mm(48") H-2438mm(96") Panel: W-1168mm(46") H-2391mm(94.13") DLO: W-965mm(38") H-2188mm(86.13")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b>	<b>Class AW-PG70 1219 x 2438 (48 x 96)-ATD</b> <b>Design Pressure: ±3360 Pa (±70 psf)</b> <b>Water Penetration Resistance Test Pressure: 580 Pa (12.11 psf)</b>

Product Tested By: Intertek- Plano, Texas  
Report No: L0767.01-801-44-R2/W-2109  
Expiration Date: **December 31, 2027**

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023