

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015607.23  
DATE: 01/23/2024  
CERTIFICATION PROGRAM: Structural  
COMPANY: Steves and Sons  
CODE: 1846-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Steves and Sons Corporation</b> <b>203 Humble Avenue</b> <b>San Antonio, TX 78225</b>	<b>Series "Regency"</b> <b>Glazed Inswing Fiberglass</b> <b>Side-Hinged Doors</b>  Configuration: XX Glazing: IG-Ext.-1/8" Annealed Glass/0.015" Opaque Film Interlayer/1/8" Annealed Glass/Int.-1/8" Tempered Glass Frame: W-1880mm(74") H-2477mm(97.50") Panel: W-908mm(35.75") H-2413mm(95") DLO: W-584mm(23") H-178mm(7")

SPECIFICATION	PRODUCT RATING
<b>ASTM E283-04</b> <b>ASTM E330-14</b> <b>ASTM E331-00</b>	<b>Design Pressure: 2160 Pa (45 psf)</b> <b>Positive Design Pressure: 2160 Pa (45 psf)</b> <b>Negative Design Pressure: 2400 Pa (50 psf)</b> <b>Water Penetration Resistance Test Pressure: 0 Pa (0.00 psf)</b>

Product Tested By: Testing Evaluation Laboratories, Inc.  
Report No: TEL 01523784 (Specimen 6)  
Expiration Date: **December 31, 2027**

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023